

Water Quality Report for City of Durand

This report covers the drinking water quality for the City of Durand for the 2009 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2009. Included in this report are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from four groundwater wells. Two are 35 feet deep and two are 70 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is **very low**.

There are no significant sources of contamination in our water supply. We have completed a comprehensive Wellhead Protection Plan (WPP) to help protect our water.


If you would like to know more about this report or our WPP please contact, Chuck Olund, Water Dept. Foreman at 989-288-3113 or Michigan State DEQ.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As

water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- Contaminants that may be present in any source water include:
 - * **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - * **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
 - * **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
 - * **Radioactive contaminants**, which are naturally occurring or may be the result of oil and gas production and mining activities.
 - * **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production. They can also come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration establishes limits for contaminants in bottled water, which provide the same protection for public health.



Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2009 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2009.

The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

*Water Supplier: Fill out the table with **only detected** contaminants. **Delete** rows that don't apply. Add rows if needed. See more instructions next page.*

Regulated Contaminant	MCL	MCLG	Your Water	Range	Sample Date	Violation Yes / No	Typical Source of Contaminant
Arsenic* (ppb)	10	0	7ppb	3-10ppb		NO	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Fluoride (ppm)	4	4	0.5ppm			NO	Erosion of natural deposits. Discharge from fertilizer and aluminum factories.
TTHM - Total Trihalomethanes (ppb)	80	N/A	.20ppm			NO	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	4ppm			NO	Byproduct of drinking water disinfection
Chlorine (ppm)	4	4	.65ppm	.51-.80ppm		NO	Water additive used to control microbes
Radioactive Contaminant	MCL	MCLG	Your Water	Range	Sample Date	Violation Yes / No	Typical Source of Contaminant
Beta emitters (pCi/L)	50 **	0	7.0		08/02	NO	Decay of natural and man-made deposits
Alpha emitters (pCi/L)	15	0	5.2		08/02	NO	Erosion of natural deposits
Special Monitoring and Unregulated Contaminant ***			Your Water	Range	Sample Date	Typical Source of Contaminant	
Sodium (ppm)			55.9ppm		1/4/06	Erosion of natural deposits	
Contaminant Subject to AL	Action Level	MCLG	90% of Samples ≤ This Level		Sample Date	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	1.0		2009	0	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	1.3	.39	.24		2009	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

* These arsenic values are effective January 23, 2006. Until then, the MCL was 50 ppb and there was no MCLG.

** EPA considers 50 pCi/l to be the level of concern for beta particles.

*** Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies of this report are available at Durand City Hall 215 W. Clinton St. Durand, MI 48429 or at www.durandmi.com/ccr.pdf. This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. The public is welcome to attend the city council meetings held at City Hall the first and third Mondays of each month at 7:30pm. For more information about your water, or the contents of this report, contact Steve Mince at 989-288-3113 X 107 or visit our web site at www.durandmi.com and for more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.